

## Peak Load Supply and Demand Plan per month for Winter FY2011 (Generating End)

&lt;Table 1: Details announced on October 4&gt;

(MW)

	Dec.	Jan.	Feb.
Peak load (A)	22,140	23,190	23,190
Supply capacity (B)	23,870	24,780	24,870
Reserve capacity (B-A)	1,730	1,590	1,680
Reserve margin (%)	7.8	6.9	7.2

&lt;Table 2: Changes to supply capacity&gt;

(MW)

	Dec.	Jan.	Feb.
Changes to schedule for periodic inspections of thermal plants (Shin-Nagoya Thermal Power Station, etc.)	-60	50	-20
Purchase of electric power from other businesses	20	110	20
Total	-40	160	0

&lt;Table 3: Peak Load Supply and Demand Plan following changes&gt;

(MW)

	Dec.	Jan.	Feb.
Peak load (A)	22,140	23,190	23,190
Supply capacity (C)	23,830	24,940	24,870
Reserve capacity (C-A)	1,690	1,750	1,680
Reserve margin (%)	7.6	7.6	7.2
( ) Increase or decrease from Table 1	(-0.2)	(+0.7)	(-)